

MAQUOKETA SPECIAL CITY COUNCIL MEETING
Monday October 12, 2020

Mayor Schwenker called the special council session of the Maquoketa City Council to order at 7:30 a.m. with six members present via Zoom Chat.

Present: Kean, Lyon, Collister, Kuhlman, Barker and Holm Absent: Woodward

Motion by Barker, seconded by Kuhlman approving the agenda. Motion Carried 6-0

Jeff Bodenoffer stated the original plans that were looked at said they were 15-inch pipe, turns out the old maps were wrong, and they were really 12-inch pipes. If they were to keep going with 12-inch pipe would create a bottle neck which would cause more issues. There is roughly 30 feet of piping that needs to be changed out.

Josh Collister asked what the new time frame was for this.

Frank Ellenz stats Mathy's will start today and then Connolly can start their portion, they are hoping an additional 2 weeks will be needed for completion.

Motion by Barker, seconded by Lyon to Approve Connolly's Change Order not to exceed \$37,000 to extend the 15" sanitary sewer pipe under a 72" storm sewer and into the manhole at the intersection of Quarry and Walnut. Motion Carried 6-0

Motion by Holm, seconded by Kuhlman adjourning at 7:45 a.m. All Ayes

Don Schwenker, Mayor

ATTEST:

Gerald Smith, City Manager